

Street lights update paper 04.04.24

Updates

- Lamp outside Elm Gables Hackwell Street (Unit 2) - JV agreed with LR that lantern would be turned through 90 degrees to run parallel to the road (pointing up hill).

Action LR

- Concrete columns – replacement steel columns all installed and connected. However concrete posts **are still in situ in Cox's Lane and on Church path. LR has been informed and asked to remove asap.**
- Southam Road – work done 07.03.24 (invoice awaited).
 - Unit 7 O/s Old House Garden (removed due to structural failure)
 - Unit 8 – opposite Green Acres

Outstanding repairs (high priority)

- Vicarage Road Unit 1 outside Arc School – LR has supplied quote. PB1 £1,248.98 exc vat. NPC confirmed acceptance of quote 20.03.24
- Howcombe Lane Unit 3 outside Pillory Thatch – **LR to provide quote**

Existing faults (non-urgent) to be done on an ad hoc basis

- Chapel Green Road Unit 2 between That'll do and Stone Weir. No action for time being
- Southam Road – Lamp opposite King Head (see plan). This is leaning and is no longer working. Google earth shows it leaning in April 21. It is unlikely to be dangerous as buried very deep.

LR has confirmed There is no legal requirement to provide lighting on the highway so it would be up to NPC to decide on how many lights we require for this stretch of road. WCC say that generally around 35m spacings would be ok to provide sufficient lighting. Parish Council lighting does not need to meet British Standards so whatever NPC decides will be ok. .

There is no obligation for NPC to provide lamps at bus stops. NPC could decide to dispense with the old leaning lamp and just leave the steel one in. This is approx 25m from the leaning one . If we wish to get old lamp replaced a separate job would be needed to return to vertical.

- Poplar Road – Unit 7. (PB3 £327.08 exc VAT 09.01.24) NPC confirmed acceptance of quote 20.03.24

New faults as at 13.03.24

- Howcombe Lane - outside The Bungalow (no action needed at present)
- Unit 1 Hillside opposite Hillside House. **LR to provide quote (priority)**

Queries

- Southam Road – Outside Fig Tree House (not sure which one this is on inventory).
- Chapel lane – brightness query- can it be dimmed?
- School Hill – unit 3 adjacent to Seymour (bottom of Church Path). Original Iffley Unit seems to have been replaced with modern lantern.

